

APPROVAL FOR CONSTRUCTION

THE PLANS AND SPECIFICATIONS FOR SEWAGE
OR WASTE DISPOSAL SYSTEM SUBMITTED FOR:

APPROVAL # 120424

Owner:

Heculano Telheiro
c/o Morgado
14 Ledge Rd.
Seabrook, NH 03842

LOT NUMBERS: 5A
SUBD. APPVL.#: 17990
SUBD. NAME:

TYPE OF SYSTEM: Three bedrooms

Copy of Plan & Approval sent to:

Board of Selectmen
Town Office
Seabrook, NH 03842

TOWN/CITY LOCATION: Seabrook, NH

STREET LOCATION: Blacksnake Rd.

By Applicant: PERMIT # 348

Anne Bialobrzewski
247 Landing Rd.
Hampton, NH 03842

PLEASE POST IN A CONSPICUOUS PLACE
DURING CONSTRUCTION.

THIS APPROVAL DOES NOT SUPERCEDE
ANY EQUIVALENT OR MORE STRINGENT
LOCAL ORDINANCES OR REGULATIONS.
STATE STANDARDS ARE MINIMAL
AND MUST BE MET STATEWIDE.

WHITE= Applicant's; YELLOW= Town's; BLUE= NHWS&PCC file; GOLD= Owner's - (No Action Required)

NOTE: (XX) Gravity system () Gravity system to septic tank and effluent pump chamber
with disposal system to be constructed on a properly prepared base.

Bed bottom to be set: () no deeper than _____ " below the original grade

() no less than _____ " above the original grade

(XX) no lower than the original grade

to maintain (XX) 4 ' minimum above (the reported) (any) seasonal high water table.

() _____ ' minimum above (the reported) (any) ledge depth.

() _____ ' minimum above (the reported) (any) impermeable soil.

(XX) Fill to prepare disposal area should be a medium to coarse sand (0.5 to 1.0 mm).

() This approval only valid for the above owner's domicile/exemption.

Approved this date:

April 18, 1985

By:

James E. Shepard

vcg

N.H. Water Supply & Pollution Control

Commission Staff

(OVER)

PERC TEST

DATE: 4/4/85

DEPTH OF HOLE: 30"

RATE OF PERC: 2 MIN/IN

DESIGN LOADING: 3 BEDROOMS

AREA REQUIRED: 560 SQ. FT.

PROPOSED SYSTEM: 20x30 FOR
600 SQ. FT. AREA PROVIDED

REVIEWED AND APPROVED
IN ACCORDANCE WITH THE
REQUIREMENTS OF THE

NEW HAMPSHIRE
WATER SUPPLY & POLLUTION
CONTROL COMMISSION

Signed

Date

PLAN OF PROPOSED
SEPTIC SYSTEM

LOCUS: LOT 5A BLACKSNAKE RD
SEABROOK, NH

OWNER: % HECULANO TELHEIRO
ANTONIO MORGADO
LEDGE ROAD
SEABROOK, NH 03874

APPLICANT: ANNE W. BIALOBRZESKI

247 LANDING ROAD

HAMPTON, N.H. 03842

DESIGNER PERMIT #348

DATE: 4/8/85


APPROVAL:

RECEIVED

APR 12 1985

WATER SUPPLY & POLLUTION
CONTROL COMMISSION

36



APPROVAL FOR CONSTRUCTION

N.H. DEPARTMENT OF ENVIRONMENTAL SERVICES
WATER SUPPLY & POLLUTION CONTROL DIVISION
P.O. BOX 95, 6 HAZEN DRIVE, CONCORD, NH 03302-0095

APPROVAL NO. 198034

THE PLANS AND SPECIFICATIONS FOR SEWAGE OR WASTE DISPOSAL SYSTEM SUBMITTED FOR:

OWNER:

EDUARDA/H TELHEIRO
% 45 MACY ST APT 203C
AMESBURY MA 01913

Lot Numbers: 5A
Subd. Appvl. No.: 17990
Subd. Name: MADELINE MAILET
County: ROCK.
Registry Book No.: 2541
Registry Page No.: 817
Probate Docket No.:
(If Applicable)

COPY SENT TO:

BOARD OF SELECTMEN
TOWN OFFICE
SEABROOK NH 03874

Type of System: 00000008R
0006756PD

Town/City Location: SEABROOK

Street Location: 88 BLACKSNAKE ROAD

BY APPLICANT: PERMIT NO. 000000348

STOCKTON SERVICES
PO BOX 1306
HAMPTON NH 03842

Subsurface waste disposal systems must be operated and maintained in a manner so as to prevent nuisance or health hazard due to system failure.
(RSA 485-A:37)

It is unlawful to discharge any hazardous chemicals or substances into subsurface waste disposal systems. Included are paints, thinners, gasoline and chlorinated hydrocarbon solvents such as TCE, sometimes used to clean failed septic systems and auto parts. (Env-Ws 410.05)

ADVISE YOUR CONTRACTOR OF REQUIRED CHANGES
IN PLANS AS INDICATED BELOW CONDITIONS

SEPTIC SYSTEM APPROVED WITH MUNICIPAL WATER SUPPLY ONLY FOR A
3 BEDROOM HOUSE & A 1 BEDROOM APARTMENT ONLY. USE OF WATER
CONSERVING PLUMBING FIXTURES IS SUGGESTED.

Approved this date:

05/12/93

By:

JOHN BAAS

Date amended:

00082676

Amended by:

(OVER)

REVISED 8/91

APPLICANT'S

PERC TEST

DATE: 4/4/85

DEPTH OF HOLE: 30"

RATE OF PERC: 2 MIN/IN

3BR = 450 GPD

1 BR = 225 GPD

DESIGN LOADING: 675 GPD

675 GPD

AREA REQUIRED: $675 \times 125 = 844$ SQ. FT.

PROPOSED SYSTEM: 20 x 43 FOR

860 SQ. FT. AREA PROVIDED

PLAN OF PROPOSED REVISED SEPTIC SYSTEM

PREVIOUS APPROVAL #120424

LOCUS: LOT 5A BLACKSNAKE RD
SEABROOK, NH

OWNER: HERCULANO & EDUARDA TELHEIRO
ANTHONY & ADELINE GEORGE
45 MACY ST APT 203C
AMESBURY, MA 01913

APPLICANT: STOCKTON SERVICES
PO BOX 1306

HAMPTON, N.H. 03842
DESIGNER PERMIT #348

DATE: 5/5/93

APPROVAL: REVIEWED AND APPROVED

IN ACCORDANCE WITH THE
REQUIREMENTS OF THE
N.H. DEPT. OF ENVIRONMENTAL SERVICES
WATER SUPPLY & POLLUTION
CONTROL DIVISION

Signed: J. Baas

Date: 5/12/93 198034

36
REVISED

ADVISE YOUR CONTRACTOR
OF REQUIRED CHANGES IN
PLANS AS INDICATED ON THIS
CONDITIONAL APPROVAL

